



Date Submitted: 6/28/2010

Water Use Efficiency Annual Performance Report - 2009

WS Name: ODESSA

Water System ID# :63050

WS County: LINCOLN

Report submitted by: Roger Sebesta

Meter Installation Information:

Is your water system fully metered? No

If not fully metered - Current status of meter installation:

Meters need to be installed at Town owned buildings, park and cemetery.

Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: 01/01/2009 To 12/31/2009

Incomplete or missing data for the year? No

If yes, explain:

Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	110,111,927 gallons
Authorized Consumption (AC) – Annual Volume	101,266,738 gallons
Distribution System Leakage – Annual Volume TP – AC	8,845,189 gallons
Distribution System Leakage – Percent DSL = $[(TP - AC) / TP] \times 100$	8.0 %
3-year annual average	%

Goal-Setting Information:

Date of Most Recent Public Forum: 06/28/2010 Has goal been changed since last performance report? No

Note: Customer goal must be re-established every 6 years through a public process

WUE Goals:

Customer Goal (Demand Side):

To maintain our less than 10% distribution leakage. To have broken meters repaired or replaced and to provide educational information on water conservation to our citizens.

Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

Broken meters have been repaired or replaced on a timely basis. The Town has less than a 10% system leakage. Information on water conservation information is available to our water customers.

Additional Information Regarding Supply and Demand Side WUE Efforts

Include any other information that describes how you and your customers use water efficiently:

The Town replaced two water reservoirs to decrease reservoir leakage, broken meters continue to be replaced or repaired. Information available to all water customers.

Do not mail, fax, or email this report to DOH